

FAX TRANSMISSION

Coushatta Convenience Store
PO Box 1107
3624 Powell Road
Elton, LA 70532
PHONE: (337) 584-1590
FAX: (337) 584-1592



TO: JOE WOMACK
FAX: 214.665-7263
FROM: Kenneth Wilson
DATE: 6-08-07
RE: CORROSION TEST

Mr. Womack, I hope this is what EPA wanted. It took me ~~over~~ a little time to get these papers. please contact me for any question.

Thank you
Kenneth Wilson



THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
 UST/SOLID WASTE SECTION (6PD-U)
 1445 ROSS AVENUE
 DALLAS, TX 75202
 TEL: 214.665.7591
 FAX: 214.665.7263

**INDIAN COUNTRY
 COMPLIANCE ASSISTANCE PLAN**
Inspection of Underground Storage Tanks (USTs)

OWNER AND/OR OPERATOR OF USTs	FACILITY
NAME <u>C. DUSHATTA TRIBE OF LA</u>	NAME <u>COUSHATTA C STORE</u>
ADDRESS <u>P.O. BOX 818</u>	ADDRESS <u>3624 PDWELL RD.</u>
CITY AND STATE <u>ELTON, LA 70532</u>	CITY AND STATE <u>ELTON, LA 70532</u>
TEL <u>(318) 584-2261</u>	TEL <u>(337) 584-1590</u> FAC ID# <u>0135 LA</u>

☐ No violations observed at the conclusion of this inspection.



The above named facility was inspected by a duly authorized representative of the United States Environmental Protection Agency (EPA). The following is the EPA Inspector's recommended corrective action plan:

- PROVIDE EPA WITH DOCUMENTATION OF LAST TWO CORROSION TESTS ON TANKS AND PUMP/DISPENSER SUMPS. INCLUDE NACE CERTIFICATION OF PERSON(S) CONDUCTING SUCH TESTS.
- PROVIDE WITHIN TWO WEEKS OF THIS INSPECTION DATE

Latitude 30° 31.411

Longitude

W 92° 42.857

Name of Owner/Operator Representative:

Kenneth W. Wilson

(Please print)

[Signature]

(Signature)

Name of EPA Representative:

JOE WOMACK

(Please Print)

[Signature]

(Signature)

Date of Inspection 05/15/07 Time 1:15 AM ☒ PM

FROM :

FAX NO. :13372372752

Jun. 06 2007 08:10AM F2

CATHODIC PROTECTION COMPLETION CERTIFICATE

COASTAL TESTING, INC.
3660 MAIN HIGHWAY
BREAUX BRIDGE, LOUISIANA 70517


**CATHODIC PROTECTION
COMPLETION RECERTIFICATE**

LASSCO
1848 1ST. ST.
LAKE CHARLES, LOUISIANA

COUSHATTA STORE
3624 POWELL RD.
ELTON, LA.

JOB DESCRIPTION - CERTIFICATION OF SACRIFICIAL CURRENT CATHODIC PROTECTION SYSTEM FOR SUBMERGED PUMP HOUSINGS AND ASSOCIATED STEEL PIPING AND FLEX HOSES BELOW DISPENSERS.

CERTIFICATION - I HEREBY CERTIFY THAT I HAVE REVIEWED THE SYSTEM REFERENCED ABOVE WITH THE RESULTS ENCLOSED HEREIN. THIS WAS DONE TO COMPLY WITH THE FEDERAL E.P.A. AND THE STATE OF LOUISIANA DIRECTIVES. THE SYSTEM PROVED TO HAVE SUFFICIENT READINGS TO PROVIDE PROTECTION FOR THE UNDERGROUND SYSTEM IN ACCORDANCE WITH THE MINIMUM STANDARDS OF THE NATIONAL ASSOCIATION OF CORROSION ENGINEERS.


TROY R. STILLEY, P.E.
CERTIFIED CORROSION SPECIALIST
NATIONAL ASSOC. OF CORROSION ENGINEERS
REGISTRATION NO. 1297

29 MAR 2007
DATE

FROM :

FAX NO. :13372372752

Jun. 06 2007 08:11AM F3

PERFORMANCE VERIFICATION

COASTAL TESTING, INC.
3660 MAIN HIGHWAY
BREAUX BRIDGE, LOUISIANA 70517

1. SYSTEM OPERATION AND ALL TEST POINTS WERE MEASURED.
2. A CONTINUITY CHECK WAS PERFORMED AND ALL STRUCTURES POTENTIALS ARE CONSISTENT.
3. ALL TANKS POTENTIALS ARE - .850 OR MORE NEGATIVE AS INDICATED ON TEST RESULTS WHEN REFERENCED TO A COPPER/COPPER SULFATE HALF CELL.
4. VOLTAGES WERE ADJUSTED IF NECESSARY.
5. ALL UNDERGROUND STRUCTURES, NOT INCLUDED IN THE CATHODIC PROTECTION SYSTEM HAVE BEEN CHECKED FOR INTERFERENCE. CHANGES TO ANY NON-SYSTEM STRUCTURES ARE NOT GREATER THAN 50 MV (0.050 VOLTS) IN A POSITIVE DIRECTION.

COASTAL TESTING, INC. GUARANTEES COMPLIANCE WITH THE ABOVE CATHODIC PROTECTION ITEMS AND AGREES TO HOLD HARMLESS TROY R. STILLEY AND GUARDIAN CORROSION CONTROL CORP. FOR ANY CLAIMS FILED AS A RESULT OF THE WORK PERFORMED BY COASTAL TESTING, INC.


PERFORMED FOR:

LASSCO
1848 FIRST ST.
LAKE CHARLES, LOUISIANA

SITE LOCATION:

COUSHATTA STORE
3624 POWELL RD.
ELTON, LA.

COASTAL TESTING, INC.
3660 MAIN HIGHWAY
BREAUX BRIDGE, LOUISIANA 70517



SIGNED: MIKE COMEAUX
TITLE: OPERATIONS MANAGER
DATE: MAY 25, 2007

06/08/2007 08:54 FAX

9 lb. mag. anodes
at all test points

dispensers

tanks

Coushatta Store
3624 Powell Road
Elton, La.

Legend

Anodes - @

Soil Borings - +

Date: 29 May 2007

Rectifier Sacrificial System

Serial #

Output Volts

Output amps

GB resistance

Hours

Sitomap I.D. CTICSHATA

On Readings

.99

1.03

1.12

1.19

1.22

Off readings

Troy R. Shroy

NACE Certified Corrosion Specialist #1297

Sitomap prepared for:

Coastal Testing, Inc.

3660 Main Highway

Breaux Bridge, La. 70517

003